



4076



**SIEVE ANALYSIS**

Report No. 1119-N-04-A-22


Client: Nick Brookes  
 Site: Wardle Depot  
 Location: Stockpile  
 Date Sampled: 20/10/11  
 Sampled from: Stockpile  
 Supplier: Client  
 Description: 20mm Pipe Bedding

Laboratory Ref: Lab/11/3986  
 Client Ref: Tr3/20/10  
 Mass (kg): 26  
 Source: Site Produced

Material Specification: BS EN 13242 - 10/20 G<sub>c</sub> 80/20 f<sub>4</sub>  
 Sampled by: PTS  
 Date received: 24/10/11  
 Sample type: Bulk  
 Method of Preparation:

Remarks: Sample complies with specification

BS Sieve (mm)	Passing (%)	Material Specification		
90				
80				
75				
63	100			
40	100		100	
31.5	100	98	-	100
20	94	80	-	99
16	50			
14	32	20	-	70
10	6	0	-	20
8.0	4			
6.3	4			
4.0	4	0	-	5
2.0	3			
1.0	3			
0.500	3			
0.250	2			
0.125	2			
0.063	1.4	0	-	4



Certified that the Particle Size Distribution was determined in accordance with EN 933-1

Signed \_\_\_\_\_  
 M.Hayes (Laboratory Manager)  
 D.Foster (Assistant Laboratory Manager)  
 J.Hopkinson (Senior Technician)