

Pavement Testing Services Ltd
Unit 7, Cowling Business Park
Canal Side, CHORLEY, PR6 0QL

T: 01257 233 242

F: 01257 234 744

E: info@ptsinternational.co.uk



4076



SIEVE ANALYSIS

Report No. 1119-N-04-A-24


Client: Nick Brookes
 Site: Wardle Depot
 Location: Stockpile
 Date Sampled: 20/10/11
 Sampled from: Stockpile
 Supplier: Client
 Description: Sand

Laboratory Ref: Lab/11/3983
 Client Ref: Tr6/20/10
 Mass (kg): 20
 Source: Site Produced

BS Sieve (mm)	Passing (%)	Material Specification
90		
80		
75		
63	100	
40	100	
31.5	100	
20	100	
16	100	
14	100	
10	100	
8.0	100	
6.3	100	
4.0	98	
2.0	90	
1.0	82	
0.500	71	
0.250	42	
0.125	16	
0.063	6.2	

Material Specification:
 Sampled by: Client
 Date received: 24/10/11
 Sample type: Bulk
 Method of Preparation:

Remarks:



Certified that the Particle Size Distribution was determined in accordance with EN 933-1

Signed _____ () M.Hayes (Laboratory Manager)
 () D.Foster (Assistant Laboratory Manager)
 (X) J.Hopkinson (Senior Technician)