

**Pavement Testing Services Ltd**  
**Unit 7, Cowling Business Park**  
**Canal Side, CHORLEY, PR6 0QL**

T: 01257 233 242

F: 01257 234 744

E: info@ptsinternational.co.uk



4076



**SIEVE ANALYSIS**


Client: Nick Brookes  
 Site: Nantwich  
 Location: Stockpile  
 Date Sampled: 09/01/12  
 Sampled from: Stockpile  
 Supplier: Client  
 Description: 40mm+ Aggregate

Report No. 1219-N-02-A-01  
 Laboratory Ref: Lab/12/03  
 Client Ref. J.2  
 Mass (kg): 40  
 Source: Site

BS Sieve (mm)	Passing (%)	Material Specification
90	100	
80	91	
75	91	
63	33	
40	2	
31.5	2	
20	2	
16	1	
14	1	
10	1	
8.0	1	
6.3	1	
4.0	1	
2.0	1	
1.0	1	
0.500	0	
0.250	0	
0.125	0	
0.063	-0.1	

Material Specification:  
 Sampled by: PTS  
 Date received: 09/01/12  
 Sample type: Bulk  
 Method of Preparation:

Remarks:



Certified that the Particle Size Distribution was determined in accordance with EN 933-1

Signed \_\_\_\_\_ ( ) M. Hayes (Laboratory Manager)  
 ( ) D.Foster (Assistant Laboratory Manager)  
 ( X ) J.Hopkinson (Senior Technician)