



**TEST CERTIFICATE**  
**PARTICLE SIZE DISTRIBUTION**

BS EN 933-1 : 1997 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Nick Brookes Group
SITE	Nick Brookes
JOB NUMBER	MRN 3043/1

SAMPLE LABEL	10-20mm Pipe Bedding	DATE SAMPLED	03-Feb-17
LAB SAMPLE No	68979	DATE RECEIVED	06-Feb-17
DATE TESTED	07-Feb-17	SAMPLED BY	Client

MATERIAL	Pipe Bedding
ADVISED SOURCE	Nick Brookes Group

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	4	
90	100		5	4	
80	100		4	3	
75	100		2	3	
63	100		1.18	3	
50	100		1	3	
40	100		0.6	2	
31.5	100		0.5	2	
28	100		0.425	1	
20	81		0.3	1	
16	43		0.25	1	
14	26		0.15	1	
10	5		0.125	1	
8	4		0.063	0.9	



REMARKS

As received moisture content = 5.7%

SIGNED

NAME O.P. Davies (Deputy Laboratory Manager) DATE 14-Feb-17