

# MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE  
GREG STREET, REDDISH, STOCKPORT SK5 7BR  
TEL 0161 475 0870 FAX 0161 475 0871



## TEST CERTIFICATE PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 1997 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Nick Brookes Group
SITE	Nick Brookes
JOB NUMBER	MRN 3043/1

SAMPLE LABEL	20-40mm Pipe Bedding	DATE SAMPLED	03-Feb-17
LAB SAMPLE No	68980	DATE RECEIVED	06-Feb-17
DATE TESTED	07-Feb-17	SAMPLED BY	Client

MATERIAL	Pipe Bedding
ADVISED SOURCE	Nick Brookes Group

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	1	
90	100		5	1	
80	100		4	1	
75	100		2	1	
63	100		1.18	1	
50	100		1	1	
40	89		0.6	1	
31.5	53		0.5	1	
28	33		0.425	1	
20	3		0.3	1	
16	1		0.25	1	
14	1		0.15	1	
10	1		0.125	1	
8	1		0.063	0.1	



### REMARKS

As received moisture content = 6.9%

SIGNED

NAME O.P. Davies  
(Deputy Laboratory Manager)

DATE 14-Feb-17