

# MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE  
GREG STREET, REDDISH, STOCKPORT SK5 7BR  
TEL 0161 475 0870 FAX 0161 475 0871



## TEST CERTIFICATE PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 1997 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Nick Brookes Group
SITE	Nick Brookes
JOB NUMBER	MRN 3043/1

SAMPLE LABEL	Recycled Type 1	DATE SAMPLED	03-Feb-17
LAB SAMPLE No	68981	DATE RECEIVED	06-Feb-17
DATE TESTED	07-Feb-17	SAMPLED BY	Client

MATERIAL	Subbase Type 1
ADVISED SOURCE	Nick Brookes Group

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	42	
90	100		5	40	
80	100		4	38	12-53
75	100		2	32	6-42
63	100	100	1.18	29	
50	92		1	28	3-32
40	87		0.6	24	
31.5	81	75-99	0.5	23	
28	77		0.425	20	
20	64		0.3	15	
16	59	43-81	0.25	12	
14	56		0.15	8	
10	50		0.125	7	
8	46	23-66	0.063	5.9	0-9



### REMARKS

Sample complies with the advised grading specification, specification shown is the overall grading specification in accordance with the specification for highway works Feb 2016.  
As received moisture content = 9.8%

SIGNED

NAME

O.P. Davies  
(Deputy Laboratory Manager)

DATE

14-Feb-17