

MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE
GREG STREET, REDDISH, STOCKPORT SK5 7BR
TEL 0161 475 0870 FAX 0161 475 0871



TEST CERTIFICATE

PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 2012 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Nick Brookes Recycling Ltd
SITE	Green Lane, Wardle, Nantwich, CW5 6DB
JOB NUMBER	MRN 3265/11

SAMPLE LABEL	10-20mm - 13	DATE SAMPLED	17-Oct-18
LAB SAMPLE No	79475	DATE RECEIVED	17-Oct-18
DATE TESTED	18-Oct-18	SAMPLED BY	Client

MATERIAL	10-20mm Pipe Bedding
ADVISED SOURCE	Nick Brookes Recycling Ltd ex Green Lane, Wardle, Nantwich, CW5 6DB

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	1	
90	100		5	1	
80	100		4	1	
75	100		2	0	
63	100		1.18	0	
50	100		1	0	
40	100		0.6	0	
31.5	100		0.5	0	
28	100		0.425	0	
20	78		0.3	0	
16	35		0.25	0	
14	16		0.15	0	
10	1		0.125	0	
8	1		0.063	0.3	



REMARKS

As received moisture content = 2.7%

SIGNED

NAME O.P. Davies BA (Hons)
(Laboratory Manger)

DATE 31-Oct-18