

MURRAY RIX

33C VAUXHALL INDUSTRIAL ESTATE
GREG STREET, REDDISH, STOCKPORT SK5 7BR
TEL 0161 475 0870 FAX 0161 475 0871



TEST CERTIFICATE

PARTICLE SIZE DISTRIBUTION

BS EN 933-1 : 2012 (Washing & Sieving Method)


Determination of water content in accordance with BS EN 1097-5:2008

CLIENT	Nick Brookes Recycling Ltd
SITE	Green Lane, Wardle, Nantwich, CW5 6DB
JOB NUMBER	MRN 3265/11

SAMPLE LABEL	5-10mm - 7	DATE SAMPLED	17-Oct-18
LAB SAMPLE No	79471	DATE RECEIVED	17-Oct-18
DATE TESTED	18-Oct-18	SAMPLED BY	Client

MATERIAL	5-10mm Pipe Bedding
ADVISED SOURCE	Nick Brookes Recycling Ltd ex Green Lane, Wardle, Nantwich, CW5 6DB

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		6.3	39	
90	100		5	19	
80	100		4	9	
75	100		2	2	
63	100		1.18	1	
50	100		1	1	
40	100		0.6	1	
31.5	100		0.5	0	
28	100		0.425	0	
20	100		0.3	0	
16	100		0.25	0	
14	100		0.15	0	
10	89		0.125	0	
8	67		0.063	0.1	



REMARKS

As received moisture content = 4.6%

SIGNED

NAME O.P. Davies BA (Hons)
(Laboratory Manger)

DATE 31-Oct-18